

CR-4 Steel Panels for Calibration

BGD 2309

Product Description

BGD 2309 CR-4 Steel Panels for Calibration CR4-grade Reference Specimens for Salt Spray Tests For a salt spray test, the corrosivity speed of test specimen not only depends on the apparatus itself, such as salt fog uniformity and working-room temperature uniformity, but also depends on all kinds of parameters set by the operator, such as volume of the collected solution, pH value of salt spray etc. In order to ensure the comparability of salt spray tests, the operator should use reference specimens to verify these influencing factors regularly. Both ISO 9227 and ISO 7253 recommend the use of CR4-grade steel as reference specimens. These specimens are in accordance with ISO 3574 with an essentially faultless surface and a matt finish (arithmetical mean deviation of the profile $R_a=0.8\mu\text{m}\pm 0.3\mu\text{m}$).



Standards

ISO 9227, ISO 7253, ISO 3574

Technical Specification

For the three salt spray tests, the allowed range of mass loss of the steel reference specimens during verification of the corrosivity of the cabinet are as mentioned below:

- A. Natural Salt Spray (NSS): After 48h testing, the allowed range of mass loss should be $70\text{g}/\text{m}^2\pm 20\text{g}/\text{m}^2$
- B. Acetic acid Salt Spray (AASS): After 24h testing, the allowed range of mass loss should be $40\text{g}/\text{m}^2\pm 10\text{g}/\text{m}^2$
- C. Copper-accelerated Acetic acid Salt Spray(CASS): After 24h testing, the allowed range of mass loss should be $55\text{g}/\text{m}^2\pm 15\text{g}/\text{m}^2$

For ISO 7253 (Paints and varnishes -- Determination of resistance to neutral salt spray (fog)), use six CR4-grade specimens. After 96 hours exposure, the allowed range of mass loss should be $130\text{g}/\text{m}^2\pm 20\text{g}/\text{m}^2$ and no individual panel should have a mass loss greater or less than $25\text{g}/\text{m}^2$ from the mean or from a value agreed by the interested parties.

BGD 2309 CR4-grade Reference Specimens for Salt Spray Tests are according with ISO 3574: Carbon content = 0.06%, Manganese content = 0.45%, Phosphorus content = 0.03%, Sulfur content = 0.03%, Surface roughness R_a is $0.8\mu\text{m}\pm 0.3\mu\text{m}$, and size is $150\text{mm}\times 70\text{mm}\times 1.0\text{mm}$.

CR-4 Steel Panels for Calibration

BGD 2309

Main Technical Parameters

Ordering Information: BGD 2309 - CR4-grade Reference Specimens for Salt Spray Tests (20 pcs/package)

Disclaimer

The information given in this sheet is not intended to be exhaustive and any person using the product for any purpose other than that specifically recommended in this sheet without first obtaining written confirmation from us as to the suitability of the product for the intended purpose does so at his own risk. Whilst we endeavour to ensure that all advice we give about the product (whether in this sheet or otherwise) is correct we have no control over either the quality or condition of the product or the many factors affecting the use and application of the product. Therefore, unless we specifically agree in writing to do so, we do not accept any liability whatsoever or howsoever arising for the performance of the product or for any loss or damage (other than death or personal injury resulting from our negligence) arising out of the use of the product. The information contained in this sheet is liable to modification from time to time in the light of experience and our policy of continuous product development